

NSF Product and Service Listings

These Listings were Last Updated on **Tuesday, April 04, 2006** at 4:15 AM Eastern Time.
Please [contact NSF International](#) to confirm the status of any Listing, report errors, or make suggestions.

Warning: NSF is concerned about fraudulent downloading and manipulation of website text. If you have received this listing in hard copy, always confirm this certification/listing information by going directly to <http://nsf.com/Certified/PwsComponents/Listings.asp?Company=54630&Standard=061&> for the latest most accurate information.

NSF/ANSI STANDARD 61 Drinking Water System Components - Health Effects

NOTE: Unless otherwise indicated for Materials, Certification is only for the Water Contact Material shown in the Listing. [Click here for a list of Abbreviations used in these Listings.](#)

CAMBRIDGE-LEE INDUSTRIES

ROUTE 61 NORTH
P.O. BOX 14026
READING, PA 19612-4026
800-523-8263
610-926-4141

Facility : READING, PA

Pipes and Related Products

Trade Designation	Size	Water Contact Temp	Water Contact Material
Tubing/Hose Seamless Copper Water Tube[1]	>= 1/4"	C. HOT	CU

[1] Copper tube (Alloy C12200) is Certified by NSF to NSF/ANSI Standard 61 for public water supplies meeting, or in the process of meeting, the U.S. EPA Lead and Copper Rule (56FR 26460, June 7, 1991). Water supplies with pH less than 6.5 may require corrosion control to limit copper solubility in drinking water.